TEST REPORT

ULR :- TC146662600004198F **T. R. No** :- OMQCPL/MT/2026/4198	**Date** : 25/02/2026

To,

Eagle Eco Industries.

Subject : Testing of Soil Stabilizes Blocks

Name of Work : CSEB Block Making

Reference Letter No. : EEI/01/2026 Date: 22/02/2025

Name of Firm/Clients: Eagle Eco Industries, Shendurni Dist. Jalgaon Maharashtra

Samples Description: Soil Stabilized Blocks	**Date of Samples Received** : 23/02/2026
Discipline/Group : Mechanical-Building Material	**Test Carried From** : 23/02/2026 to 24/02/2026
Lab Sample ID : SSB/MT/4198/2026	
No. of Samples : 03	**Test Method & SP** : IS 1725:1982 RA-2011
Sample Condition : Good	
Environmental Condition : 28.3 °C	

TEST RESULT

Dimension: - 300x150x90 (mm)

Sr. No.	Test Name	Identification No.	Test Results Kg/sq.cm	Specified Limits as per IS 1725:1982 RA-2011
1	Compressive Strength	B1	149.69	The Min Compressive Strength Shall not less than 20 kg/sq.cm for class 20 & 30 kg/sq.cm for class 30
		B2	140.72	
		B3	143.88	

Terms And Condition:

1) The test report and result relate particular specimen sample of the material as delivered /received and tested in the laboratory.

2) Any test report shall not be reproduced expect in full without the written Approval from OMQCPL.

3) The consultancy cell will bear no responsibility what so ever (Legal or otherwise) pertaining to any dispute involving client's party or the material.

4) If client has any comment it should be receive by the cell within one week of the report. After that no objection will be entertained.

QUALITY CONTROL CELL OM CONSULTANT PVT. LTD.

Authorized Signatory
Pankaj Bhangale [QM]